

BUILDING INSPECTION NOTICE

B-4. Complete

Permit #: 1 9 - 1 2 1 5 3 6 - M F

LI: _____

Supervisor Tel: 408 535-7651

Confirmation #:

0	1	8	1	5	0	4	0
---	---	---	---	---	---	---	---

Received: 06/04/2019

By: Phone

Preferred:

Scheduled:	0	6	/	0	8	/	1	9
------------	---	---	---	---	---	---	---	---

Tract:

Lot:

of Units:0 Map: 834 C 6

Address: 96 S 6TH ST SAN JOSE

Contact: LEO

Phone: (408) 390-2302

ETA Call: Y

Owner: LEE JOHNNY

Contractor: PRIME HOME BUILDERS INC

Primary: (408)390-2302

Folder Name: (B 100%) STAIR REPAIR

Subtype: Apartment

Work Proposed: Additions/Alterations

Comments:

Related Permits:

Insp Time:

Inspection time listed at the left includes 10 minutes travel time.

Next Inspections Suggested

Number of Units:

Time inspection completed

[illegible]

Remarks:

Remarks:

1. STAIR HEIGHTS / RISERS NOT TO CODE - PROVIDE 36" LANDING AT BOTTOM OF STAIR TO CORRECT 1st RISER HEIGHT.
2. PROVIDE GRASPABLE HAND RAILS
3. RAIL AT SIDE IS INADEQUATE AS GUARD - THIS IS B. ONLY.
4. HAND RAIL EXTENSION MAY BE OMITTED FOR 1' IN T.

You have a total of 1.16 hour(s) remaining on this project as of Friday, June 07, 2019 12:51:18 PM.

Inspector's Signature: _____

Print:

DL 10734

Date: 66 / 08 / 19

Page: \ of